

# Water Testing Results - Veneta Elementary School

## Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Front Office Health Room Restroom	20840300-001BF	1/11/2023	ND
Staff Lounge Restroom Faucet - South	20840300-002BF	1/11/2023	ND
Staff Lounge Restroom Faucet - North	20840300-003BF	1/11/2023	ND
Staff Lounge Kitchen Sink	20840300-004SF	1/11/2023	ND
Room 1 - Classroom Sink	20840300-005CF	1/11/2023	2.8
Room 1 - Classroom Drinking Fountain	20840300-006DW	1/11/2023	4.56
Room 2 - Classroom Sink	20840300-007CF	1/11/2023	3.96
Room 2 - Classroom Drinking Fountain	20840300-008DW	1/11/2023	2.9
Room 3 - Classroom Sink	20840300-009CF	1/11/2023	ND
Room 3 - Classroom Drinking Fountain	20840300-010DW	1/11/2023	ND
Restroom- Room 4 - Boys - North Sink	20840300-011BF	1/11/2023	2.16
Restroom- Room 4 - Boys - South Sink	20840300-012BF	1/11/2023	3.91
Restroom - Room 4 - Girls - North Sink	20840300-013BF	1/11/2023	2.6
Restroom - Room 4 - Girls - South Sink	20840300-014BF	1/11/2023	6.1
North Atrium Drinking Fountain	20840300-015DW	1/11/2023	<b>21.5</b>
New Wing Restroom Sink-Left to Right - 1	20840300-016BF	1/11/2023	ND
New Wing Restroom Sink-Left to Right - 2	20840300-017BF	1/11/2023	ND
New Wing Restroom Sink-Left to Right - 3	20840300-018BF	1/11/2023	ND
New Wing Restroom Sink-Left to Right - 4	20840300-019BF	1/11/2023	ND
Room 5 - Classroom Sink	20840300-020CF	1/11/2023	ND
Room 5 - Classroom Drinking Fountain	20840300-021DW	1/11/2023	ND
Room 6 - Classroom Sink	20840300-022CF	1/11/2023	ND
Room 6 - Classroom Drinking Fountain	20840300-023DW	1/11/2023	ND
Room 7 - Classroom Faucet	20840300-024CF	1/11/2023	ND
Room 7 - Classroom Drinking Fountain	20840300-025DW	1/11/2023	ND
Room 8 - Classroom Faucet	20840300-026CF	1/11/2023	ND
Room 8 - Classroom Drinking Fountain	20840300-027DW	1/11/2023	ND
Kallio Commons Sink	20840300-028CF	1/11/2023	ND
Kallio Commons Sink Sprayer	20840300-029CF	1/11/2023	ND

Room 9 - Classroom Sink	20840300-030CF	1/11/2023	ND
Room 9 - Classroom Drinking Fountain	20840300-031DW	1/11/2023	ND
Room 10 - Classroom Sink	20840300-032CF	1/11/2023	ND
Room 10 - Classroom Drinking Fountain	20840300-033DW	1/11/2023	ND
Room 11 - Classroom Sink	20840300-034CF	1/11/2023	3.11
Room 11 - Classroom Drinking Fountain	20840300-035DW	1/11/2023	3.23
Drinking Fountain Hallway North of Library Near Exit	20840300-036DW	1/11/2023	2.86
Room 12 - Classroom Sink	20840300-037CF	1/11/2023	<b>14.9</b>
Room 12 - Classroom Drinking Fountain	20840300-038DW	1/11/2023	<b>17</b>
Restroom - Boys - Near Room 13	20840300-039BF	1/11/2023	ND
Room 13 - Classroom Sink	20840300-040CF	1/11/2023	<b>19.3</b>
Room 13 - Classroom Drinking Fountain	20840300-041DW	1/11/2023	<b>32.1</b>
Room 14 - Classroom Sink	20840300-042CF	1/11/2023	10.3
Room 14 - Classroom Drinking Fountain	20840300-043DW	1/11/2023	3.28
Restroom - Girls - Near Room 14	20840300-044BF	1/11/2023	ND
Room 15 - Classroom Sink	20840300-045CF	1/11/2023	<b>18.1</b>
Room 15 - Classroom Drinking Fountain	20840300-046DW	1/11/2023	<b>12.3</b>
Room 17 - Classroom Sink	20840300-047CF	1/11/2023	5.39
Room 17 - Classroom Drinking Fountain	20840300-048DW	1/11/2023	11.2
Room 18 - Classroom Sink	20840300-049CF	1/11/2023	10.5
Room 18 - Classroom Drinking Fountain	20840300-050DW	1/11/2023	7.39
Room 19 - Classroom Sink	20840300-051CF	1/11/2023	2.05
Room 19 - Classroom Drinking Fountain	20840300-052DW	1/11/2023	<b>13.1</b>
Room 20 - Classroom Sink	20840300-053CF	1/11/2023	6.23
Room 20 - Classroom Drinking Fountain	20840300-054DW	1/11/2023	<b>18.5</b>
Room 21 - Classroom Sink	20840300-055CF	1/11/2023	10.6
Room 21 - Classroom Drinking Fountain	20840300-056DW	1/11/2023	<b>16.1</b>
Drinking Fountain Near Room 22	20840300-057DW	1/11/2023	11.7
Bottle Fill Fountain Near Room 22	20840300-058WB	1/11/2023	4.7
Gymnasium Restroom Sink - Left	20840300-059BF	1/11/2023	ND
Gymnasium Restroom Sink - Right	20840300-060BF	1/11/2023	ND
Gymnasium Drinking Fountain - Left	20840300-061DW	1/11/2023	ND
Gymnasium Drinking Fountain - Right	20840300-062DW	1/11/2023	3.2
Cafeteria Sink Faucet - Left	20840300-063CF	1/11/2023	ND
Cafeteria Sink Faucet - Middle	20840300-064CF	1/11/2023	ND

Cafeteria Sink Faucet - Right	20840300-065CF	1/11/2023	2.77
Cafeteria Sink Drinking Fountain	20840300-066DW	1/11/2023	ND
Cafeteria Restroom - Girls	20840300-067BF	1/11/2023	ND
Cafeteria Restroom - Boys	20840300-068BF	1/11/2023	ND
Kitchen - Hand Wash Sink - Left of Three (3) Well Sink	20840300-069KF	1/11/2023	ND
Kitchen - Three (3) Well Sink - Left	20840300-070KF	1/11/2023	ND
Kitchen - Three (3) Well Sink - Right	20840300-071KF	1/11/2023	ND
Kitchen - Dedicated Wall Sprayer Before Dishwasher	20840300-072KF	1/11/2023	18.9
Kitchen - Prep Sink - West Side of Room	20840300-073KF	1/11/2023	ND
Kitchen - Hand Wash Sink - West Side	20840300-074KF	1/11/2023	ND
Kitchen - Spray Wand on 3 well sink Faucet #71	20840300-075KF	1/11/2023	ND

**Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing**

**RETESTS**

North Atrium Drinking Fountain	20840300-015DW	4/26/2023	10.8
Room 12 - Classroom Sink	20840300-037CF	4/26/2023	ND
Room 12 - Classroom Drinking Fountain	20840300-038DW	4/26/2023	ND
Room 13 - Classroom Sink	20840300-040CF	4/26/2023	6.14
Room 13 - Classroom Drinking Fountain	20840300-041DW	4/26/2023	4.16
Room 15 - Classroom Sink	20840300-045CF	4/26/2023	ND
Room 15 - Classroom Drinking Fountain	20840300-046DW	4/26/2023	6.56
Room 19 - Classroom Drinking Fountain	20840300-052DW	4/26/2023	2.41
Room 20 - Classroom Drinking Fountain	20840300-054DW	4/26/2023	2.41
Room 21 - Classroom Drinking Fountain	20840300-056DW	4/26/2023	22.5
Room 21 - Classroom Drinking Fountain	20840300-056DW	6/1/2023	9.14
Kitchen - Dedicated Wall Sprayer Before Dishwasher	20840300-072KF	1/26/2023 - Removed from Service	

**ND = Non Detect - Lead level is below the set detection limits of X ppb**