

Elmira High School HASS Water Testing Summary

11/17/24

Initial HASS water testing was completed on 2/28/23. A total of 113 samples were collected in accordance with ODE guidelines. Of those samples, 10 were above the allowable limit and one was borderline for a total of 11 fixtures. All of the fixtures were removed from service until remediation could be performed. Fixtures 20840415-001DW and 20840415-002DW were completely removed and no longer exist. Fixtures 20840400-059OS, 20840414-001OS and 2084015-002OS were replaced with new fixtures. The remaining fixtures were retested in accordance with ODE guidelines. All of the fixtures retested within the allowable limits.